

2023年5月度

項目名称	NO _x -1 溶融量	NO _x -2 溶融量	ごみ合計	NO _x -1 炉頂温度 1炉	NO _x -2 炉頂温度 2炉	NO _x -1 減温塔出口 温度	NO _x -2 減温塔出口 温度	煙突排 化水素 濃度成分	煙突排 ばいじん 濃度成分	算(1)NO _x -1 換	煙突排 ガス成分 2換	算(2)NO _x -2 換	煙突排 ガス成分 2換	算(3)NO _x -1 換	煙突排 ガス成分 2換	算(4)NO _x -2 換	煙突排 ガス成分 2換
(基準値)								50	10	100	50	30	0.1				
(単位)	t	t	t	°C	°C	°C	°C	ppm	mg/m ³ N	ppm	ppm	ppm	ngTEQ/m ³ N				
1(月)	59.96	61.40	121.36	1185	1173	170	170	2	0	51	0	11					
2(火)	59.08	59.81	118.89	1181	1163	170	170	2	0	51	0	10					
3(水)	59.77	59.76	119.53	1181	1156	170	170	3	0	52	0	9					
4(木)	52.35	62.03	114.38	1181	1161	170	170	2	0	50	0	10					
5(金)	58.03	62.23	120.26	1185	1173	170	170	3	0	50	0	9					
6(土)	59.38	61.67	121.05	1182	1183	170	170	3	0	51	0	13					
7(日)	60.62	62.22	122.84	1184	1173	170	170	2	0	51	0	14					
8(月)	59.69	58.44	118.13	1182	1186	170	170	2	0	50	0	11					
9(火)	57.62	61.51	119.13	1187	1169	170	170	2	0	51	0	9					
10(水)	61.93	60.58	122.51	1181	1181	170	170	3	0	52	0	11					
11(木)	59.75	63.89	123.64	1181	1164	170	170	3	0	50	0	12					
12(金)	59.81	62.40	122.21	1186	1174	170	170	3	0	50	0	10					
13(土)	77.07	26.37	103.44	1184	1130	170	170	3	0	50	0	14					
14(日)	42.71	0.00	42.71	1072		172		5	1	27	0	17					
15(月)	75.38	0.00	75.38	1179		170		3	0	39	7	15	0.0000031				
16(火)	86.55	0.00	86.55	1172	炉頂ダクト整備	170	炉頂ダクト整備	3	0	50	8	14	4/19測定				
17(水)	62.06	0.00	62.06	1141		170		5	1	48	6	16					
18(木)	86.16	0.00	86.16	1188		170		4	0	48	9	11					
19(金)	83.59	0.00	83.59	1186		170		3	0	42	3	14					
20(土)	87.24	0.00	87.24	1184		170		4	0	42	13	10					
21(日)	73.47	23.40	96.87	1177	1188	170	174	4	0	47	16	9					
22(月)	60.49	58.05	118.54	1168	1183	170	170	3	0	49	3	8					
23(火)	59.52	55.45	114.97	1176	1188	170	170	2	0	50	1	7					
24(水)	61.25	63.78	125.03	1174	1173	170	170	3	0	51	2	7					
25(木)	61.03	60.28	121.31	1181	1184	170	170	3	0	50	0	7					
26(金)	59.54	48.58	108.12	1184	1168	170	170	3	0	52	0	9					
27(土)	62.09	58.27	120.36	1165	1183	170	170	3	0	52	0	8					
28(日)	59.68	57.48	117.16	1182	1189	170	170	3	0	50	0	11					
29(月)	57.23	58.82	116.05	1180	1186	170	170	3	0	50	0	10					
30(火)	61.28	59.53	120.81	1171	1184	170	170	3	0	51	0	7					
31(水)	59.99	62.19	122.18	1180	1180	170	170	3	0	50	1	9					

